

*Groundwater Determinations Within  
the Westvue Meadows Subdivision*

**PURPOSE**

The purpose of this procedure is to insure adequate protection of the ground water aquifer.

**GENERAL**

Observation of groundwater test pits during wet-weather conditions has demonstrated groundwater at or near the surface of the ground in observation pits on slopes of 5% or greater.

**AUTHORITY**

Direction from North Coast Regional Water Quality Control Board., Dated January 4, 1978  
North Coast Basin Plan, Sonoma County Code Chapter 7,  
Uniform Plumbing Code

**PROCEDURE**

All private sewage disposal installations within the West View Meadows Subdivision must comply with depth to groundwater requirements found within the North Coast Water Quality Control Board Basin Plan without waiver. Due to soil conditions in this Subdivision, the direct observation method for determining depth to groundwater (as defined in Section III, B, 3b of the policy on the Control of Water Quality with respect to On-Site Waste Treatment and Disposal Practices) shall apply on every lot, regardless of ground slope.

**Attachment:**

January 4, 1978 Letter from WQCB  
Map

Approved by:

Date Posted: 9/27/02

/s/ Richard L. Holmer

**Richard L. Holmer, Operations Manager**

Intranet       Intranet and Internet